

NTI Boilers Inc. Tel: (506) 657-6000 Toll Free: 1-800-688-2575 Web: www.ntiboilers.com Email: info@ntiboilers.com

## 6000053035 Matrix Furnace Blower (less Motor)

## Applicable Boiler Models

• Matrix M100(V)

## Kit Contents

• Furnace Blower (less motor)



NOTICE

**Mounting rail Transfer:** The mounting rails must be transferred from the old blower to the new one. Care must be used to maintain the correct positioning of the rails to ensure

proper mouting if the new blower.

## **Replacement Instruction**

- 1) Remove the old blower motor
- 2) Remove the self tapping screw secuting the mounting rails
- 3) Use a drill and driver to screw the rails to the new blower in the same locaiton



Remove and transfer Mounting Rails to the new blower



S:\NTI2001\_N\_Drive (1-20-09)\R&D\PARTS - ENGINEERING\Parts Department Stickers and Instructions\Engineering Only\Current Parts Instructions (doc and pdf)\Parts Instructions Word Docs